

## **ADDENDUM NO. 1**

2 July 2026

To All Bidders on the Project titled:

### **Massachusetts Military Division**

Massachusetts Army National Guard (MAARNG) Camp Edwards  
Procurement, Installation and Annual Inspection/ Maintenance for Camp Edwards, MA  
MMD Project No. 260686

JFHQ-MA

Massachusetts Military Division  
2 Randolph Road, Hanscom AFB, MA  
Bedford, MA 01731

Reference Statement of Work dated July 2026

The attention of bidders submitting bids for the above subject project is called to the following addendum to the Statement of work. The items set forth herein, whether of omission, addition, substitution, or clarification are all to be included in and form a part of the bid submitted.

#### Item No.1:

**Change to Contract Documents- Statement of Work Section 03000 – Add the following:**

**3.2.2.3 All fire extinguishers must be installed on a wall and with a wall mount bracket provided by the contractor. Wall material includes but not limited to CMU, Concrete, drywall, and various types of lumber. Wall mounted brackets must be tied into a stud if the wall contains wood studs. An identification sign or sticker must be above the extinguisher installed. It is not required to install an identifying sign/sticker if there is already one in place.**

**3.2.2.7 If an extinguisher is already in place; the contractor can decide to recharge the extinguisher that is already in place or replace with a new extinguisher.**

PLEASE BE ADVISED TO ACKNOWLEDGE THIS ADDENDUM ON THE BID FORMS.

---- End of Addendum No. 1 ----